

## Summary of 2014 Update to Water Engineering Standards

<b>2013 Water Engineering Standards</b>	<b>2014 Water Engineering Standards</b>	<b>Revision</b>
throughout document	throughout document	Change 2013 to 2014
NA	Add Section W1-05	Add Paragraph requiring lead content in all fixtures in contact with potable water must meet Federal requirements.
W2-04.2	W2-04.2	8th paragraph starting with "Datum -"; Change "NSRS 2007" to "NSRS 2011"
W2-05.1	W2-05.1	2nd paragraph starting with "As-Built"; Change "NSRS 2007" to "NSRS 2011"
W3-04	W3-04	Add "unless approved by the utility department" to last sentence in third to last paragraph.
Standard Drawing W-2, W-3, W-5	Standard Drawing W-2, W-3, W-5	Contractor said ss316 Cooper B-line B3132 pipe clamp is not available in stainless steel and mfg also says it is not available in stainless steel.
Standard Drawing W-6	Standard Drawing W-6	Add "12" min." dimension to drawing on Tee patch from back of trench to existing pavement surface.
Appendix W-4	Appendix W-4	Revise approved material list; Cooper B-Line B3132– Heavy Duty Hot Dipped Galvanized pipe clamps (embedded in concrete blocks)US Pipe (TR FLEX)

